



**SIRIM QAS INTERNATIONAL SDN. BHD.** (410334-X)

1, Persiaran Dato' Menteri, Seksyen 2, Peti Surat 7035, 40700 Shah Alam, Selangor Darul Ehsan, Malaysia  
Tel : 60-3-5544 6400 Faks : 60-3-5544 6797 www.sirim-qas.com.my

File No : P5-000117  
Licence No : LH000603

Date : 28/07/2021

HUME CEMBOARD INDUSTRIES SDN. BHD.  
NO.12, JALAN TANDANG,  
46050 PETALING JAYA  
SELANGOR, MALAYSIA

Attn : MR.RAMESHVARAN RAJASINGAM

Tel No : 03-77811977

Fax No : 03-77820293

Dear Sir/Madam,

**Fire Listing Licence**

Product : FIBRE-CEMENT FLAT SHEETS  
Standard : BS 476 : PART 7 : 1997 BS 476 : PART 6 : 1989

---

With regards to your request for new/renewal/changes of licence(s) under the SIRIM Fire Listing Licence scheme, enclosed please find the copy of the licence(s) and the certification report(s) for your safe keeping.

For enquiry, please contact

Officer Name : MUHAMMAD FADIL ARSAD BIN MOHD USOPE  
Contact No : 603-55445863  
Email : arsad@sirim.my

Thank you.

*This is a computer generated document. No signature is required.*

# SIJIL BARANGAN TERSENARAI

## *Product Listing Certificate*



**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada**  
*SIRIM QAS International Sdn. Bhd. hereby grants to*

**HUME CEMBOARD INDUSTRIES SDN. BHD.**  
**NO.12, JALAN TANDANG,**  
**46050 PETALING JAYA**  
**SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai**  
*a certificate to use the Listed Product Mark on*

**FIBRE-CEMENT FLAT SHEETS**

**Please refer to detail in the SCHEDULE**

**sebagai mematuhi keperluan**  
*as complying with*

**BS 476 : PART 7 : 1997**  
**BS 476 : PART 6 : 1989**



**Nur Fadhilah binti Muhammad**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.



# SCHEDULE

**HUME CEMBOARD INDUSTRIES SDN. BHD.**



Trade Mark : CITY FLAT, PRIMAFLEX  
Rating : Fire propagation Index, I = 0.1;  
Surface Spread of Flame: Class One  
Type : Smooth surface  
Size : Nominal Thickness (3.2mm) x Nominal Width (600, 1200mm) x Nominal Length  
(1200mm)  
Test report : 2017FE0081, 2017FE0080

Trade Mark : PRIMAFLEX  
Rating : Fire propagation Index, I = 2.1;  
Surface Spread of Flame: Class One  
Type : Smooth surface  
Size : Nominal Thickness (3.5mm) x Nominal Width (600, 1200mm) x Nominal Length  
(1200mm)  
Test report : 2017FE0077, 2017FE0079

TEST REPORT NO. : 2017FE0077, 2017FE0079, 2017FE0080, 2017FE0081

---

*End of page*

---